

# CERTIFICATE

Issued to:  
Applicant:  
**Mete Enerji Kablo ve Elektrik Malzemeleri San ve.  
Tic. A.S.**  
**A.O.S.B. 10007 Sok No: 34  
35620 Cigli Izmir, Turkey**

Licensee:  
**Mete Enerji Kablo ve Elektrik Malzemeleri San ve.  
Tic. A.S.**  
**A.O.S.B. 10007 Sok No: 34  
35620 Cigli Izmir, Turkey**

Product : 2-pole socket-outlet  
Trade name(s) : ME  
Type(s)/model(s) : 4040xxxxxx

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard NEN 1020:2019, NEN-IEC 60884-1:2019, NEN-IEC 60884-1:2019/A1:2019 and NEN-IEC 60884-1:2019/A2:2019
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2155515


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 16 October 2019 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-110510

DEKRA Certification B.V.



B.T.M. Holtus  
Managing Director



R Zhou  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	: 2-pole socket-outlet
Trade name(s)	: ME
Type(s)/model(s)	: 4040xxxxxx
Rated current	: 16 A
Rated voltage	: 250 V~
Standard sheet	: III of the CEE 7
Degree of protection	: IP44 or IP54
Method of mounting	: panel type, screw-fixing
Design	: rewirable, fixed
Terminals	: screw terminals
Earthing	: with side earthing contacts
Markings	: -tradename series-indication and electrical ratings on the base -tradename and suffix for the cover on this part

**TESTS****Test requirements**

NEN 1020:2019  
NEN-IEC 60884-1:2019  
NEN-IEC 60884-1:2019/A1:2019  
NEN-IEC 60884-1:2019/A2:2019

**Test result**

The test results are laid down in DEKRA test file 223572200.

**Conclusion**

The examination proved that all requirements were met.

**Factory location**

Mete Enerji Kablo ve Elektrik Malzemeleri San ve. Tic. A.S.  
A.O.S.B. 10007 Sok No: 34  
35620 Cigli Izmir, Turkey